

APPENDIX – VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

NO.CMO 4582

DATE – 26-08-2023

It is Certified that **GLOBAL INTERNATIONAL SCHOOL, FARM WALI NAHAR, RAMPUR** has safe drinking water facilities for the students and members of staff of the institution as per the norms prescribed by the State Govt.

This Certificate is issued on basis of District Level Water Analysis Laboratory, UPJN (Rural), Rampur water testing report on dated 21-08-2023.

The above Valid for a period of **26-08-2023 to 25-08-2024**

  
CHIEF MEDICAL OFFICER,  
RAMPUR.  


TO  
GLOBAL INTERNATIONAL SCHOOL,  
Opp. JAUHAR HOSPITAL, FARM WALI NAHAR, RAMPUR  
(Name & Address of the Institution)



## District Level Water Analysis Laboratory,UPJN(Rural),Rampur

### Water Analysis Report

Report No- RMP/LAB/03

Date of Report- 21.08.2023

Customer Detail:- Global international School

Office Name and Address

Opp. To Jauhar Hospital, Farm wali Nahar, Rampur

Ref.Letter No.

GIS/RMP/223/23 DATE-18.08.2023

### Basic Detail Of Sample

District	RAMPUR	Block	
Gram Panchayat	-	Village	
Habitation	-	Location	School
Water Source	DEEP TUBE WELL	Sample No.	C/23/08/063
Quantity of Sample	1000 ML(Normal And Acidic)	Date of S.C	19.08.2023
Receiving Date	19.08.2023	Sample Collector	ZAHID HUSSAIN
Sample Depositor	ZAHID HUSSAIN		
Analysis Start Date	19.08.2023	Analysis End Date	21.08.2023

### MICROBIOLOGICAL PARAMETERS

S.No	Analysed Parameter	Obseved Value	Specified Value As Per BIS 10500:2012		Reference Method Of Analysis
			Acceptable Limit	Permissible Limit	
1	E.Coli	Absent	Shall not be detectable in any 100 ml sample		IS 15185:2016
2	Total Coliform	Absent			IS 15185:2016

*Kingh*  
MICROBIOLOGIST

### Technical Data Record

S.No	Analysed Parameter	Obseved Value	Specified Value As Per BIS 10500:2012		Reference Method Of Analysis
			Acceptable Limit	Permissible Limit	
1	pH	7.81 at 28.2°C	6.5-8.5	No Relaxation	IS3025(Part 11)
2	TDS(Mg/L)	202	500	2000	IS3025(Part 16)
3	Turbidity(NTU)	0.26	1	5	IS3025(Part 10)
4	Colour(HU)	1	5	15	IS3025(Part 4)
5	Taste	Agreeable	Agreeable	Agreeable	IS3025(Part 7and 8)
6	Odour	Agreeable	Agreeable	Agreeable	IS3025(Part 5)
7	Total Hardness(Mg/L)	165	200	600	IS3025(Part 21)
8	Total Alkanity(Mg/L)	192	200	600	IS3025(Part 23)
9	Chloride(Mg/L)	13	250	1000	IS3025(Part 32)
10	Calcium(Mg/L)	40.8	75	200	IS3025(Part 40)
11	Magnesium(Mg/L)	15.37	30	100	IS3025(Part 46)
12	Nitrate(Mg/L)	0.21	45	No Relaxation	APHA 23rd Edition :4500 NO3
13	Sulphate(Mg/L)	10.25	200	400	APHA 23rd Edition :4500 SO4
14	Iron(Mg/L)	0	0.3	No Relaxation	APHA 23rd Edition :4500 Fe

\*\*End of The Report\*\*

\*NOTE: This Water is Suitable for Drinking Purpose.

\*These Parameters Are Out Of NABL Scope, BDL-Below Detection Limit,NT-Not Tested,mg/L-miligram per litre,NTU-Nephelometric Turbidity

ANALYSED BY

Laboratory Contact Detail-E-mail-labjalnigamgramin@gmail.com

NOTE: 1)This Certificate Refers Only to The Particular sample Submitted for Testing. (2)This Certificate Shall Not Be Reproduced Except In Full ,unless written Permission for the Publication Of an Approved Abstract Has Been obtained From Head Of Laboratory (3)The Test Results Reported in This Certificate are Valid at The Time of And Under The Stated Conditions Of Measurements (4)Sample Will Be Stored Up to 7 Days ( In case of Non Perishable items Only) From The Date of Issue.

