



**District Level Water Analysis Laboratory,
U.P Jal Nigam (Rural), Rampur
(NABL Certified Laboratory)**



Report No- RMP/LAB/21

Water Analysis Report

Customer Detail:- Global International School

Date of Report- 01-04-2025

Office Name and Address

Opp.to Jauhar Hospital,Farm Wali Nahar,Rampur

Ref.Letter No.

GIS/RMP/365/2025

Basic Detail Of Sample			
District	RAMPUR	Block	-
Gram Panchayat	-	Village	-
Habitation	-	Location	-
Water Source	DEEP TUBE WELL	Sample No.	C/25/03/P/06
Quantity of Sample	1000 ML(Normal And Acidic)	Date of S.C	29.03.2025
Receiving Date	29.03.2025	Sample Collector	Anmol Shakhdar
Sample Depositor	Anmol Shakhdar		
Analysis Start Date	29.03.2025	Analysis End Date	01.04.2025

Technical Data Record

S.No	Analysed Parameter	Observed Value	Specified Value As Per BIS 10500:2012		Reference Method Of Analysis
			Acceptable Limit	Permissible Limit	
1	pH	7.09 at 25.5°C	6.5-8.5	No Relaxation	IS3025(Part 11)
2	TDS(Mg/L)	198	500	2000	IS3025(Part 16)
3	Colour(HU)	0	5	15	IS3025(Part 4)
4	Fluoride(Mg/L)	0.162	1	1.5	IS3025(Part 60)
5	Total Hardness(Mg/L)	146	200	600	IS3025(Part 21)
6	Total Alkalinity(Mg/L)	172	200	600	IS3025(Part 23)
7	Chloride(Mg/L)	13.5	250	1000	IS3025(Part 32)
8	Calcium(Mg/L)	32.4	75	200	IS3025(Part 40)
9	Magnesium(Mg/L)	15.86	30	100	IS3025(Part 46)
10	Nitrate(Mg/L)	0.248	45	No Relaxation	APHA 24rd Edition :4500 NO3
11	Sulphate(Mg/L)	4.24	200	400	APHA 24rd Edition :4500 SO4
12	Iron(Mg/L)	0.0	1.0	No Relaxation	APHA 24rd Edition :3500 Fe


End of The Report

*NOTE: This Water is Suitable for Drinking Purpose.

*These Parameters Are Out Of NABL Scope, BDL-Below Detection Limit, NT-Not Tested, mg/L-miligram per litre, NTU-Nephelometric Turbidity unit, HU-Hazen Unit.

Analysed By

Laboratory Contact Detail-E-mail-labjalnigamgramin2@gmail.com



NOTE: 1) This Certificate Refers Only to The Particular sample Submitted for Testing. (2) This Certificate Shall Not Be Reproduced Except In Full unless written Permission for the Publication Of an Approved Abstract Has Been obtained From Head Of Laboratory (3) The Test Result Reported in This Certificate are Valid at The Time of And Under The Stated Conditions Of Measurements. (4) Sample Will Be Stored Up to 7 Days (In case of Non Perishable items Only) From The Date of Issue.

Annexure C

PERFORMA FOR THE SAFE DRINKING WATER AND SANITARY COBDITION CERTIFICATE

NO.

Dated:

It is certified that an inspection team headed by Mr. Rohit Kumar (SWSM)

(Name of Officers with Designation) from Assistant Engineer PHED

Inspected the Global International School, Rambur

(Name & Address of school) on 29.03.2025 (date of inspection) and on the basis of water

Test Report (Attached) bearing no. RMP/Lab/21 dated 01.04.2025

Of District Level Water Analysis Lab (PHED Lab) certified that the

Global International School (Name of school) has safe drinking water facilities for

The Students and members of the staff of the institution. School is also maintain the hygienic sanitation

Conditions in the school building & the campus as per norms prescribed by Central /State /U.T.Govt.

This certificate is valid till 31-03-2026


Assistant Engineer
Division Office, UP Jal Nigam (Rambur)

Signature with Seal :

Name : Rohit Kumar

Designation : AE

Name & Address of the Office /Department:

To

Global International School, Rambur.

Opp. Touhar Hospital, Rambur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies.